

## **CORRIGENDUM TO THE TENDER DOCUMENT**

The following Corrigendum to the Tender Document is hereby issued:-

S. N	Title of the clause	Existing	To be read as
1	Corrigendum no.2, Page no.2, Point no. 2 -Eligibility criteria -Eligibility Conditions	OEM Bidder / Manufacturer should have ISO 9001:2015 certified manufacturing facility and ISO 14001:2015 certified for handling hazardous products/BIS Certificates for 1KVA to 5KVA	OEM Bidder / Manufacturer should have ISO 9001:2015 certified manufacturing facility and ISO 14001:2015 certified for handling hazardous products and BIS Certificates shall be submitted atleast for any one of the UPS System ranging from 1KVA to 10KVA and should be submitted with 20 days from the date of tender submission.
2	Wiring Items for 10 KVA, 15KVA and 20KVA Online UPS Systems – New Items added in Price Bid – Annexure-2 Add on items (SI.No.83 to 86)		DB Box 12 way 25 Amps Single Pole MCB 4 Sq. mm Cable Single run DB Box 8 way
3	Wiring Items for 7.5KVA Online UPS Systems – New Items added in Price Bid – Annexure-2 Add on items (SI.No.87 to 94)		Input Isolator with MS Enclosure 63A - 2 Pole  Input Wiring: Cable 16sq.mm 2run & 6sq.mm 1 run  Output MCB with Enclosure 32A 2 Pole  Output Wiring: Cable 10sq.mm 2run & 6sq.mm 1 run  Switch & Socket: 5A-3pin Switches & Sockets 1 No with Gang box  5A-3pin Switches & Sockets 1 set with Gang Box  15A Plug & Socket with box  Earthing for 7.5KVA