

Rate Contract Tender

**Supply and Installation of UPS Systems and
Related items**

**Tender Ref.
ELCOT/PROC/OT/33125/UPS Systems and Related items/2018- 19**

CORRIGENDUM TO THE TENDER DOCUMENT

The following Corrigendum to the Tender Document is hereby issued:-

S. N	Title of the clause	Existing	To be read as
1	Page no.14, Clause No: 4-4.1, Point no. 8 -Eligibility criteria –Eligibility Conditions	OEM Bidder / Manufacturer should have ISO 9001:2015 certified manufacturing facility and ISO 14001:2015 certified for handling hazardous products.	OEM Bidder / Manufacturer should have ISO 9001:2015 certified manufacturing facility and ISO 14001:2015 certified for handling hazardous products/BIS Certificates for 1KVA to 5KVA
2	Page No.14, Clause No: 4-4.1, Point no. 5 -Eligibility criteria-Documentary Proof to be submitted	Copies of the Audited Annual Reports containing the Balance sheets and Profit and Loss account for the last 3 Audited Financial years. (2015-16, 2016-17 & 2017-18)	Copies of the Audited Annual Reports containing the Balance sheets and Profit and Loss account for the last 3 Audited Financial years. (2014-15, 2015-16 & 2016-17)
3	Page No.14, Clause No: 4-4.1, Point no. 5 -Eligibility criteria- Eligibility Conditions	The OEM Bidder shall have an Annual Turnover of Rs.10 Crores or above in the last three Successive Audited Financial Years.	The OEM Bidder shall have an Annual Turnover of Rs.5 Crores or above in the last three Successive Audited Financial Years.
4	Page No.14, Clause No: 4-4.1, Point no. 6 -Eligibility criteria- Eligibility Conditions	The OEM Bidder shall have executed Single order for supply, installation and commissioning of UPS Systems for a value of at least Rs. 50 Lakhs and above for any Government Departments / Organisations / Public Sector Undertakings in India in the last 3 years.	The OEM Bidder shall have executed Single order for supply, installation and commissioning of UPS Systems for a value of at least Rs. 50 Lakhs and above for any Government Departments / Organizations / Public Sector Undertakings in Tamil Nadu in the last 3 years.
5	Page No.14, Clause No: 4-4.1, Point no. 7 -Eligibility criteria- Eligibility Conditions	The OEM bidder should have atleast one service centre in each region (North, East, South and West as given in the Tender Document) with a total of minimum 10 service centres in the State. The service centre may be run by Manufacturer or Franchise or authorised distributors/dealers.	The OEM bidder should have atleast one Zonal service centre in each region (North, East, South and West as given in the Tender Document) with a total of minimum 10 service centres in the State. The Zonal service centre should be run by the OEM. Other service centres may be run by OEM/Franchise.

6	Page No.14, Clause No: 4-4.1, Point no. 7 -Eligibility criteria- Documentary Proof to be submitted	In case of OEM's Own Service Centre, copies of the land-line telephone bills or valid rent agreement as on tender opening date shall be submitted as a proof for availability of the service centres. Incase of OEM's Franchisee Service centre ,copy of the valid agreement entered between the Franchisee and the OEM Bidder shall be submitted.	In case of OEM's Own Zonal Service Centre, copies of the land-line telephone bills as on tender due date (i.e month before the due date) shall be submitted as a proof for availability of the service centres. In case of OEM's Franchise Service centre, copy of the valid agreement entered between the Franchisee and the OEM Bidder shall be submitted.
7	Page no.65, Clause No: 9-9.1, Point no. A -Sample submission	a) For each item quoted in the Tender, the samples should be submitted indicating the make, model number and brochures / specification of the items for testing by ELCOT as per Appendix-3 of the Tender.	Sample submission shall be done as per Tender Clause 9.2 in the tender document
8	Page no.52, Clause No: 7-7.2, Point no. 2 - Tender Validity	2. The Rate Contract will be valid for 1 year from the date of signing of the contract or agreement/date of release of the first Purchase order, whichever is later. However ELCOT reserves the right to extend or short close the Tender validity period if situation warrants to benefit the Government.	2. The Rate Contract will be valid for 2 years from the date of signing of the contract or agreement/date of release of the first Purchase order, whichever is later. However ELCOT reserves the right to extend or short close the Tender validity period if situation warrants to benefit the Government.
9	Page no.96, Clause No: A1-A1.5, Serial No. 4, Item Code - Hardware Compliance	Item Code LIA 1000 - 30 LIA 1000 - 60 LIA 1000 - 120 LIA 1000 - 240	Item Code OL 1000 - 30 OL 1000 - 60 OL 1000 - 120 OL 1000 - 240
10	Page no.96, Clause No: A1-A1.5, Serial No. 8, Item Description - Hardware Compliance	Item Description 5 KVA On-Line	Item Description 7.5 KVA On-Line
11	Page no.17, Specifications - Code No. LIA 600-30 - Point No.8- Nominal Voltage	Output Nominal Voltage – 220V / 230V AC, Output Voltage Regulation (+/-1%)	Output Nominal Voltage – 220V / 230V AC, Output Voltage Regulation (+/-10%)
12	Page no.38, Specifications - Code No. 10 KVA On-Line OL10000-30 OL10000-60	DB9, RS232, Smart Slot, USB	RS 232 OR USB

	OL 10000-120-Point No.36 -Interface Ports		
13	Page no.37, Specifications - Code No. 10 KVA On-Line OL10000-30 OL10000-60 OL 10000-- Point No.23 - Ambient Temperature range	10 to 50deg Cel	0 to 50 deg Cel
14	Page no.41, Specifications - Code No. 15 KVA On-Line OL15000-30 OL15000-60 OL 15000-120-Point No. 22- Ambient Temperature range	10 to 50deg Cel	0 to 50 deg Cel
15	Page no.45, Specifications - Code No. 20 KVA On-Line OL20000-30 OL20000-60 OL 20000-120-Point No. 22- Ambient Temperature range	10 to 50deg Cel	0 to 50 deg Cel
16	Page no.42, Specifications - Code No. 15 KVA On-Line OL15000-30 OL15000-60 OL 15000-120-Point No.35- Interface ports	DB-9 RS-232,Smart-Slot, USB	RS-232 or USB
17	Page no.46, Specifications - Code No. 20 KVA On-Line OL20000-30 OL20000-60 OL 20000-120-Point No.35- Interface ports	DB-9 RS-232,Smart-Slot, USB	RS-232 or USB