

Electronics Corporation of Tamil Nadu Ltd
MINUTES OF PRE BID MEETING
Tender Ref: ELCOT/ ITPD/SHO - SEZ / IT TOWER / ADDL INFRA/2019
Pre Bid Meeting Date and Time :
27-08-2019 AT 3:00 PM

Sub: Providing infrastructure facilities such as site Grading, Parking arrangements, Approach Road, Drain and Rear side compound wall in Plot No. 9 of ELCOSEZ at sholinganallur, Chennai.

ELCOT

1. Mr. K.Murugan, EE
2. Mr. N.M. Kumar, Manager (ITPD)
3. Mr. P.N.S. Mahesh Babu, AEE
4. Mrs. S. Vijayakumar D.M (Finance)
5. Mrs. V. Aruna Devi D.M (F&A)
6. Mrs. G. Mangayarkarasi D.M (Sect& Legal)
7. Mrs. A. Kiruba Ranjini D.M (ITPD)

Consultant

M/s. CRNarayana Rao Consultants

Bidders

1. M/s. R.K. & Sons, Salem
2. M/s. P.S.K. Engineering Construction & Co.,, Namakkal
3. M/s. V.R Earth Movers & Constructions (P) Ltd., Ekattuthangal
4. M/s. T. Narasimhan Contractor, Chengelpet

BIDDERS QUERY AND REPLY

Sl. No	Clause No./ Page No.	As per tender Documents	Bidders Queries	Reply	Remarks
1			Presence of Batching Plant in the proposed work area	This issue will be decided during execution of works.	
2			Approach Road for execution of work.	common Road at site is Available.This can be used.	
3			Location of Labour Shed inside the campus.	The labour shed inside the campus is not allowed.Contractor has to make on his own arrangement out side the ELCOT premises	

Sl. No	Clause No./ Page No.	As per tender Documents	Bidders Queries	Reply	Remarks
4	PART - A 16 / 67	All works under or in course of execution executed in pursuance of the contract shall at all times be open and accessible to the inspection and supervision of the Employer / Engineer or his Supervisory Officers, his authorised assistant in charge of the work. The Contractor shall at all times, during the usual working hours and all other times at which reasonable notice of the visit of such officers has been given to the Contractor, either himself be present to receive orders and instructions or have a responsible representative duly accredited in writing, present for that purpose. Orders given to the Contractor's agent shall be considered to have the same value as if they have been given to the Contractor himself.	Clarification of Working Hours for execution of works	As per Prevailing Tender conditions.	

Sl. No	Clause No./ Page No.	As per tender Documents	Bidders Queries	Reply	Remarks
5	PART - E 1 / 17&18	Installation of Vertical Bored cast in situ RCC piles in all types of soils and socketting in hard rock to a minimum depth of 1.5m or 2.5 times the dia of pile which ever is less , using Ready Mix Concrete of M30 grade, with sulphate resistant Cement, fine aggregate, 20mm and down graded HBGS jelly coarse aggregate. The rate includes cost of reinforcing steel, binding wire, fabrication, welding charges, placing of reinforcement cage in bore hole in correct position, cost of boring to the required depth with Bentonite solution with temprory casing of required length, conveyance of RMC to site and pouring concrete using Tremine pipes, conveyance of all materials to the site including all tools and plants, shifting the plants and equipments from one point to another, excavation of mud pits for circulation of Bentonite solution,	Technical specification for Under Reamed Piles.	The Technical Specification of Under reamed pile is "Installation of Vertical Bored cast in situ RCC under reamed piles of 450mm dia in all types of soils to a minimum depth of 4.00 m with intermediate two Bulb , using Ready Mix Concrete of M30 grade, with sulphate resistant Cement, fine aggregate, 20mm and down graded HBGS jelly coarse aggregate. The rate includes cost of reinforcing steel of 8 nos 16mm dia with 8 mmstirrups at 150 mm c/c tied with binding wire, fabrication, welding charges, placing of reinforcement cage in bore hole in correct position, cost of boring to the required depth with Bentonite solution with temprory casing of required length, conveyance of RMC to site and pouring concrete using Tremine pipes, conveyance of all materials to the site including all tools and plants,	

Sl. No	Clause No./ Page No.	As per tender Documents	Bidders Queries	Reply	Remarks
		closing the mud pits to original level and mud removal with initial lead and lift but including dismantling the concrete above the cut off level etc complete as directed by the departmental officers including socketing. The reinforcement cage should be welded properly for lifting. The concrete cubes to be tested as per IS 456-2000. Acceptance criteria by clause 16.1.		shifting the plants and equipments from one point to another, excavation of mud pits for circulation of Bentonite solution, closing the mud pits to original level and mud removal with initial lead and lift but including dismantling the concrete above the cut off level etc complete as directed by the Engineer -incharge. The reinforcement cage should be welded properly for lifting. The concrete cubes to be tested as per IS 456-2000. Acceptance criteria by clause 16.1. "	
		Frequency of testing should be as per clause 15.2.2. The length of pile for payment shall be measured up to natural ground level. The work should be carried out as per IS 2911. Pile depth should be decided by the departmental office at site.			

Sl. No	Clause No./ Page No.	As per tender Documents	Bidders Queries	Reply	Remarks
		450mm dia Pile having longitudinal main reinforcement of 8 nos.16mm dia with helical reinforcement at 8mm dia at 200mm c/c with inner rings of 12mm dia @ 1000mm c/c with lifting hook of 12mm dia at required length			
6			Clarification for If the Quantity exceeds over the BOQ Quantity.	Tentative QTY is given in the BOQ.If Variation arises during execution of work,obtaining prior approval from consultant (PMC)/ELCOT	
7			Clarification for Dewatering of stagnated water at site in the proposed filling area.	to be Pumped into the ELCOT(Main Entry)Storm water Drain.	
8	PART - A e-tender notice / 4	ELCOT is a Developer under SEZ Act and rules. All supplies made to ELCOT are Zero rated under IGST. Therefore the quoted price to exclude all output taxes on supplies to ELCOT.	Clarification for GST Reimbursement	As per Prevailing Tender conditions.	

Sl. No	Clause No./ Page No.	As per tender Documents	Bidders Queries	Reply	Remarks
9	PART - A 4.3 (e) / 19	ELCOT at its discretion may or may not extend the due date and time for the submission of bids on account of amendments.	Time Extension for submission of Tender.	Time has been extended as per Corrigendum No. 2	